



**Underwriters  
Laboratories Inc.®**

**Northbrook Division**  
333 Pfingsten Road  
Northbrook, IL 60062-2096 USA  
www.ul.com  
tel: 1 847 272 8800  
fax: 1 847 272 8129  
Customer service: 1 877 854 3577

COOPER INDUSTRIES INC BUSSMANN DIV  
MR. DAN GIBLIN  
PO BOX 14460  
ST LOUIS MO 63178

**RE: Project Number(s) - 07NK14235**

Your most recent Certification is shown below. Please review the text and contact the Customer Service Professional who assisted with your project if revisions are required.

To view your company's current Listing Information or for ordering Listing Information in the 3 x 5-inch card format, please refer to [www.ul.com](http://www.ul.com).

JFHR  
Special-purpose Fuses

September 25, 2007

COOPER INDUSTRIES INC BUSSMANN DIV  
PO BOX 14460, ST LOUIS MO 63178

E56412

---

Special plug fuses, nonrenewable, Cat No S.  
Special cartridge fuses, nonrenewable, Cat No JJNT.  
Cat Nos ECF-1/2 to 8 incl, rated 125 v ac.  
Cat Nos KRP-C, LPJ, LPN-RK, LPS-RK, SP/LPJ followed by ampere rating, followed by SP.  
Cat Nos LPN-RK, LPS-RK followed by ampere rating, followed by TPSP.  
Cat No JJNXX-1J0283 where "XX" is amp rating 61-100 A. Rated 300 v, ac.  
Cat Nos RWA 1-20A, RWB 1-30A, RWC 70-100A, RWD 70-200A all rated 600 v ac, 300 v dc  
Cat No TCF 1-100 rated 600 v ac, 300 v dc, meeting Class J fuse performance requirements and suitable for branch circuit protection  
Cat No TCFXXN rated 1-30A, 600 v ac, 300 v dc, meeting Class J fuse performance requirements and suitable for branch circuit protection  
Cat No LPS-RK followed by ampere rating, of 3 -60A followed by SPI rated 600v ac, 300v dc.  
Cat No LPN-RK followed by ampere rating, of 35-60A, followed by SPI rated 250v ac, 125v dc  
Cat Nos SCV8, SCV15, SCV20 rated 600 Vac

**LOOK FOR LISTING MARK ON PRODUCT**

